

COMMISSIONERS: STAN VANDERWERF (CHAIR) CAMI BREMER (VICE-CHAIR)

HOLLY WILLIAMS CARRIE GEITNER LONGINOS GONZALEZ, JR.

FINANCIAL SERVICES DEPARTMENT

IFB NO. 21-099

Х

DUE DATE: August 5, 2021

#### ADDENDUM NO. 1 For ASPHALT REPLACEMENT AT 17 N SPRUCE STREET PARKING LOT

# DATE OF ADDENDUM: August 2, 2021

**THE ATTACHED** addendum shall become as fully a part of the above named Invitation for Bid (IFB) as if therein included and shall take full and complete precedence over anything contained to the contrary.

**ACKNOWLEDGMENT:** Each proposer shall indicate acknowledgment of receipt of this addendum by signing below and submitting this addendum (this page only) with the proposal.

Each proposer shall be responsible for reading every item on the attached addendum to ascertain to what extent and in what manner it affects the work being proposed.

No attempt is made to list Addendum items in chronological order or in conformity with the Drawings to which they refer or which they affect.

# NO CHANGE TO DUE DATE CHANGE DUE DATE TO: N/A

I acknowledge receipt of this addendum which shall become a part of the submitted proposal.

COMPANY NAME

AUTHORIZED REPRESENTATIVE

**15 EAST VERMIJO** 

OFFICE: (719) 520-6390

SIGNATURE

A COLUMN COLUMN

WWW.ELPASOCO.COM

COLORADO SPRINGS, CO 80903 FAX: (719) 520 -6730

PHONE

TITLE

DATE

IFB No. 21-099 ASPHALT REPLACEMENT AT 17 N. SPRUCE STREET PARKING LOT Addendum No. 1 Page 2

The following is hereby made a part of this solicitation.

#### VENDOR QUESTIONS/CLARIFICATIONS:

- 1. The following Attachments are being added to this Addendum:
  - a. 21-099 Sign-in Sheet
  - b. Revised BID FORM
  - c. ADA Striping Plan
- 2. Has the parking lot been resurfaced before? Per County records the parking lot has not been

resurfaced, only patched.

- 3. Can the parking lot be closed for a day? Yes.
- 4. Can you provide the stripping plan for this parking lot? Yes.
- 5. Would the County consider a concrete pavement overlay alternate, in leu of the asphalt removal and replacement? Propose concrete as add/alt pricing for the ADA Parking spaces. Asphalt replacement for the total parking lot, please.
- 6. Could you please verify that you would like for us to bid 4" removal and 4" replace? Roll to a compacted depth of three (3) inches and smooth for a consistent finish.

### END OF ADDENDUM NUMBER ONE

All other terms and conditions of the original IFB shall remain unchanged and the subsequent proposals received as a result of this solicitation shall be opened and evaluated in accordance with those terms and conditions.

Please sign the addendum signature page and return it with your proposal. Failure to acknowledge this addendum in writing may be cause for rejection of your proposal.

Mark E Means 11

Mark Means Procurement Specialist