

EL PASO  **COUNTY**
COLORADO

COMMISSIONERS:
STAN VANDERWERF (CHAIR)
CAMI BREMER (VICE-CHAIR)

HOLLY WILLIAMS
CARRIE GEITNER
LONGINOS GONZALEZ, JR.

FINANCIAL SERVICES DEPARTMENT

IFB NO. 21-126

DUE DATE: November 15, 2021

ADDENDUM NO. 2
For
REMOVE AND INSTALL AIR HANDLING UNITS AT SHERIFF'S OFFICE

DATE OF ADDENDUM: October 21, 2021

THE ATTACHED addendum shall become as fully a part of the above named Invitation For Bid (IFB) as if therein included and shall take full and complete precedence over anything contained to the contrary.

ACKNOWLEDGMENT: Each proposer shall indicate acknowledgment of receipt of this addendum by signing below and submitting this addendum (this page only) with the proposal.

Each proposer shall be responsible for reading every item on the attached addendum to ascertain to what extent and in what manner it affects the work being proposed.

No attempt is made to list Addendum items in chronological order or in conformity with the Drawings to which they refer or which they affect.

<input type="checkbox"/>	NO CHANGE TO DUE DATE
<input checked="" type="checkbox"/>	CHANGE DUE DATE TO: <u>BID DUE DATE IS 2:00 PM (MT), NOVEMBER 15, 2021</u>

I acknowledge receipt of this addendum which shall become a part of the submitted proposal.

COMPANY NAME

PHONE

AUTHORIZED REPRESENTATIVE

TITLE

SIGNATURE

DATE



The following is hereby made a part of this solicitation.

I. PRE-BID SITE VISIT

1. An additional pre-bid site visit shall be held at **3:00 PM (MT), Thursday, October 28, 2021** at the El Paso County Sheriff's Office located at 27 E. Vermijo, Colorado Springs, CO 80903. When attending the pre-bid site visit, please bring your business card.
2. Questions related to this site visit shall be directed to Mark Means, Procurement Specialist, Contracts & Procurement Division, e-mail: markmeans@elpasoco.com. All technical questions must be submitted by **no later than 2:00 PM (MT), Tuesday, November 2, 2021** via Rocky Mountain E-Purchasing System at www.bidnetdirect.com.

II. BID OPENING

The call-in information for the IFB 21-126 Bid-Opening has changed to the following:

Instructions (Participant-guest) login:

1. Dial access number: **1-720-279-0026**
2. Enter the participant-guest pass code: 514880#

III. VENDOR QUESTIONS/CLARIFICATIONS:

1. Per E-602 May the 60amp Disconnect be reduced to a 40 amp Disconnect with 40amp fuses as Clearance problems Exist in each Mech. Room?

Yes, we use 60A because they are standard, if 40A disconnects are available they are acceptable to be used in place of 60A disconnects.

2. No New 3 pole 40amp Contactor is shown between the New Disconnect and the AHU VFD. Controls will be taken directly to VFD by others. No 120v ckt or conduit run is planned for a contactor.

Correct, controls are by other and is not shown on this set of plans.

3. Request for Facilities to Power Off "MDP" as to bring large (4 Total) # 3/0 200amp rated wire through Top of Gear to designated bucket and Land. Install 3/0 Lug for Neutral Wire and #6 Ground wire on Main Ground Bar.

Yes, EPC Facilities will power-off MDP.

4. Will EPC take care of temporary heating/cooling if any is required while one side of the builds AHU will be shut down?

Yes.

5. Will EPC cover the warranty and start-up of the owner supplied units?

Yes.

6. If one of the concrete louvers happen to break what will be expected to happen since replacement are not available?

EPC will replace any broken louvers.

7. Will parking be allowed behind the sheriff's office?

Yes, four (4) vehicles max.

END OF ADDENDUM NUMBER TWO

All other terms and conditions of the original IFB shall remain unchanged and the subsequent proposals received as a result of this solicitation shall be opened and evaluated in accordance with those terms and conditions.

Please sign the addendum signature page and return it with your proposal. Failure to acknowledge this addendum in writing may be cause for rejection of your proposal.

Mark E Means 99

**Mark Means
Procurement Specialist**