

EL PASO COUNTY

COLORADO

COMMISSIONERS:
STAN VANDERWERF (CHAIR)
CAMI BREMER (VICE-CHAIR)

HOLLY WILLIAMS
CARRIE GEITNER
LONGINOS GONZALEZ, JR.

FINANCIAL SERVICES DEPARTMENT
EILEEN GONZALES, CPPO, CPPB – CONTRACTS & PROCUREMENT MANAGER

IFB NO. 22-029

DUE DATE: MARCH 16, 2022

ADDENDUM NO. 2
For
HVAC ROOFTOP UNIT (RTU) PROJECT

DATE OF ADDENDUM: FEBRUARY 28, 2022

THE ATTACHED addendum shall become as fully a part of the above named IFB as if therein included and shall take full and complete precedence over anything contained to the contrary.

ACKNOWLEDGMENT: Each bidder shall indicate acknowledgment of receipt of this addendum by signing below and submitting this addendum (**this page only**) with the bid.

Each bidder shall be responsible for reading every item on the attached addendum to ascertain to what extent and in what manner it affects the work being proposed.

No attempt is made to list Addendum items in chronological order or in conformity with the Drawings to which they refer or which they affect.

<input checked="" type="checkbox"/>	NO CHANGE TO DUE DATE
<input type="checkbox"/>	CHANGE DUE DATE TO:

I acknowledge receipt of this addendum which shall become a part of the submitted proposal.

COMPANY NAME

PHONE

AUTHORIZED REPRESENTATIVE

TITLE

SIGNATURE

DATE

15 EAST VERMILJO AVE.
OFFICE: (719) 520 – 6390



COLORADO SPRINGS, CO 80903
FAX: (719) 520 -6730

The following is hereby made a part of this solicitation:

QUESTIONS:

The following questions were submitted:

1. Please provide electrical details for the new RTU.
County response: Electrical detail drawings were included in an attachment to Addendum No.1.
2. Will there be a second site visit to review the electrical scope once the details have been provided by the Engineer?
County response: No second site visit is planned.
3. Will the county accept a digital thermostat that utilizes all the capabilities of the new RTU or is it required that the new RTU be connected to the existing BAS?
County Response: New RTU unit must tie into existing BAS.
4. Please provide the contact information of the preferred roofing contractor.
County response: Roof repairs must be performed by a Carlisle-certified roofer as membrane is still under warranty. The County has no preferred contractor, just that they be certified. Use of a non-certified roofer will void the warranty.

ATTACHMENTS:

1. Pre-Bid Sign-In Sheet.

END OF ADDENDUM NUMBER TWO

All other terms and conditions of the original IFB shall remain unchanged and the subsequent bids received as a result of this solicitation shall be opened and evaluated in accordance with those terms and conditions.

Please sign the addendum signature page and return it with your bid. Failure to acknowledge this addendum in writing may be cause for rejection of your bid.

David Carey

David Carey, CPPB
Procurement Specialist