
**THIS ADDENDUM SHALL BECOME A PART OF THE SOLICITATION
AND MUST BE ACKNOWLEDGED**

**Request for Proposal (RFP) 22-089 – Road Resurfacing Projects AFR1-AFR2 Construction Management -
Dated May 27, 2022**

CLARIFICATIONS:

El Paso County will only accept electronic bid proposals submitted through the Rocky Mountain E-Purchasing system. A Submittal Log will be posted after the County has had an opportunity to review and verify the submittals offered to the County.

The original Offer must be received before the due date and time through electronic package through the Rocky Mountain E-Purchasing system. The Vendor is responsible for ensuring their proposal is posted by the due date and time outlined in the solicitation document.

If the submittal arrives late, it will not be included in the electronic lockbox.

ADMINISTRATION:

- The question period has expired
- We will be verifying submittals include the following:
 - Addendum(s) Acknowledgement (if any)
 - Statement of Qualifications - SF FORM 330
 - Specimen copies of requested Insurance Certificate(s)
 - Qualification Statement
 - Project Plan
 - Exceptions to contract documents (if any)
 - Byrd Anti-Lobbying Certificate
 - Non-Collusion Affidavit

If a submittal is missing any of the above-mentioned documentation the submittal may be returned to the vendor as non-responsive and be deemed ineligible to participate.

RESPONSE TO QUESTIONS:

1. The bid date is on a Monday. Sub's and suppliers do not like having their price out for very long. Changing it to Tuesday would allow them to give us prices on Monday. **Bid date has been changed to Wednesday, June 22, 2022 at 2:00 PM MST as per Addendum No. 1.**
2. Can we use rotomill tailings instead of crushed concrete? **Yes.**

3. The project total bid sheet shows full width milling. There are three different thicknesses. Can you break it out for the three different ones? Also, there is no thickness listed for the bridge deck milling. **Yes, bid line item separated (see revised bid form for IFB 22-084). Bridge deck milling shall be 2".**

Signature below indicates that applicant has read all the information provided above and agrees to comply in full. This addendum is considered as a section of the Request For Proposal and therefore, this signed document shall become consideration and fully submitted with the original package.

PRINT OR TYPE YOUR INFORMATION

Company Name: _____ Fax: _____
Address: _____ City/State/Zip: _____
Contact Person: _____ Title: _____
Email: _____ Phone: _____
Authorized Representative's Signature: _____ Date: _____
Printed Name: _____ Title: _____
Email: _____ Phone: _____